



For ConTech Lighting Pendant Track Adapter: LA-17A

- 1. Turn off power.
- 2. Cut pendant cord to desired length and strip end of wires to prepare for connection.
- 3. Thread pendant cord through bottom cover of track adapter. The set screw hub of the bottom cover should be facing out toward the pendant.
- 4. Make the wire connections. Connect the white wire to neutral and the black wire to line voltage. Connect the Green/Yellow wire to ground.
- 5. Push wire nuts and wires into the track adapter housing. Place bottom cover of track adapter into place making sure the polarity indicator arrow on the cover points in the same direction as the polarity indicator arrows on the track adapter latch. Use two (2) included screws to attach the cover to the track adapter.
- 6. Using a flat head screwdriver tighten strain relief set screw on track adapter bottom cover securely against pendant cord.

IMPORTANT SAFETY INSTRUCTIONS:

- Read all the instructions before installation. Save instructions for later use.
- Turn off the power at fuse or circuit breaker box before installation or any maintenance work.
- Wear rubber soled shoes and work on a sturdy wooden or non-conductive ladder.
- Product must be mounted in locations and at heights in compliance with National Electrical Code and local building codes.
- For indoor use only.
- Do not exceed the nominal supply voltage or amperage ratings.
- Suitable for field wiring with 18 AWG, Min 105°C type SJT flexible cord.
- Rated to support a max of 10 lbs. luminaire weight.
- Installing contrary to instructions may cause unsafe conditions.
- Warning: Risk of fire. Most dwellings built before 1985 have supply wire rated at 60°C. Consult a qualified electrician before installation.
- To avoid hazards to children, account for all parts and properly dispose of all packing materials.
- Call the Technical Support department at ConTech Lighting with any installation questions.

